

Read this document carefully before using this device. The guarantee will be expired by damaging of the device if you don't attend to the directions in the user manual. Also we don't accept any compensations for personal injury, material damage or capital disadvantages.

# **ENDA ETM442 DIGITAL TIMER**

Thank you for choosing ENDA ETM442 digital timer.

### \* 48x48mm sized.

- \* 2x4 digits display.
- \* Easy to use by front panel keypad.
- \* Selectable 9 different time bases between 0-99.99s and 0-9999h.
- \* Selectable PNP or NPN sensor type.
- \* Selectable up/down counting direction for time.
- \* Adjustable Minimum On and Off times for pulses.
- \* Operation with or without memory for each output type.
- \* 9 different output types.
- \* Bottom display can be adjusted to show time unit or set value.
- \* Selectable functional reset.
- \* Parameter access protection on 3 levels.
- \* Easy connection by removable screw terminal.
- \* CE marked according to European Norms.

Order Code : ETM442-

1

ETM 442

OUT

DIGITAL TIMER

Supply Voltage 230VAC...230V AC 24VAC....24V AC SM......9-30V DC / 7-24V AC

# **TECHNICAL SPECIFICATIONS**

ENVIRONMENTAL CONDITIONS			
Ambient/storage temperature	0 +50°C/-25 +70°C (with no icing)		
Max. relative humidity	80% up to 31°C decreasing linearly 50% at 40°C.		
Rated pollution degree	According to EN 60529 Front panel : IP65 Rear panel : IP20		
Height	Max. 2000m		

No not use the device in locations subject to corrosive and flammable gases.

ELECTRICAL CHARACTERISTICS		
Supply	230V AC +10% -20%, 50/60Hz or 24V AC ±10%, 50/60Hz or optional 9-30V DC / 7-24V AC ±10% SMPS	
Power consumption	Max. 5VA	
Wiring	2.5mm <sup>2</sup> screw-terminal connections	
Date retention	EEPROM (Min. 10 years)	
EMC	EN 61326-1: 2006	
Safety requirements	EN 61010-1: 2010 (pollution degree 2, overvoltage category II)	

INPUTS		
START input	Input types can be adjusted as PNP or NPN in programming mode.	
GATE input	Minimum On and Off times for input pulses can be adjusted between 5 and 100ms. For PNP input types, active level is 5 to 30V pulse,	
RESET input	For NPN input types, active level is 0 to 2V pulse.	

OUTPUTS		
Control output (OUT)	Relay : 250V AC, 2A (for resistive load), NO+NC	
	Open collector output (S.S. OUT): Max. 30V DC, 100mA	
Auxiliary power supply	12V DC, max. 50mA (without regulation)	
Life expectancy for relay	Mechanical 30.000.000 operation; Electrical 300.000 operation	
Accuracy	± 0.1% ± 20ms	

Note : Relay and S.S.OUT outputs are in synchronization . When OUT relay is energized S.S. OUT transistor goes into saturation.

HOUSING		
Housing type	Suitable for flush-panel mounting according to DIN 43 700.	
Dimensions	W48xH48xD87mm	
Weight	Approx. 210g (after packing)	
Enclosure material	Self extinguishing plastics	
While cleaning the device, solvents (thinner, benzine, acid etc.) or corrosive materials must not be used.		


## TERMS


	<ul> <li>(2) Set value or time unit du Parameter value, unit or (3) Output LED.</li> <li>(3) Output LED.</li> <li>(4) Increment key during rur Parameter selection key</li> <li>(5) Parameter selection and Decrement key during ru</li> <li>(6) Used for selecting oPt</li> <li>(7) Used for selecting run or</li> </ul>	emonic parameter code during programming mode. Iring run mode. r mnemonic parameter code during programming mode.
(1) PV display	4 digits, 7 segment red LED	
(2) SV display	4 digits, 7 segment yellow LED	
Character height	PV display (1): 7.1mm SV display (2): 7.1mm	
(3) Output LED	One red LED	
( 4 ),( 5 ),( 6 ),( 7 ) Keypad	Micro switch	
DIMENSIONS	Depth 87mm 2 - 1 - 1 - 1 	Panel cut-out
	<ul> <li>While pressing both side of the device in direction 1, push it in direction 2.</li> </ul> Flush mounting	<ul> <li>Note: 1) While panel mounting, additional distance required for connection cables should be considered.</li> <li>2) Panel thickness should be maximum 9mm.</li> <li>3) If there is no 100mm free space at back side of the device, it would be difficult to remove it from the panel.</li> </ul>

## **CONNECTION DIAGRAM**




ENDA ETM442 is intended for installation in control panels. Make sure that the device is used only for intended purpose. The shielding must be grounded on the instrument side. During an installation, all of the cables that are connected to the device must be free of energy. The device must be protected against inadmissible humidity, vibrations, severe soiling. Make sure that the operation temperature is not exceeded. All input and output lines that are not connected to the supply network must be laid out as shielded and twisted cables. These cables should not be close to the power cables or components. The installation and electrical connections must be carried on by a qualified staff and must be according to the relevant locally applicable regulations.







### **OUTPUT TYPES**



Po Starl Reset Relay t1 ∏ t2 ∞ t2 t1 t2  $\infty$ t1 + t2 = T OFF



Config. 8 Timing on energization with memory



T OFF

t2

t1 + t2 = T OFF

 $\infty$ 

t2 ∞ t ∞ t1 While the device is energized.

If START is active, relay is energized after delay time (TOFF). If START becomes passive before TOFF time, timer waits for another active signal at the START input to complete the TOFF time.

While the device is energized,

If START is active, relay is energized after delay time (TOFF) If START becomes passive before TOFF time

timer waits for another active signal at the START input to complete the TOFF time.

If START becomes passive after TOFF time, reset occurs. Relay is de-energized and initial condition is returned.


NOTE: if Gate input becomes active, timer enters into wait mode. Timer waits at that condition until gate input becomes passive

While the device is energized, If START input is active, relay becomes first Off and then On periodically during TOFF and TON times respectively. As soon as START becomes passive, timer stops and initial conditions are returned.

With an impulse at the START input, relay becomes On.

However, timer do not counts while START is active. When START becomes passive, relay becomes Off after

With an impulse at the START input, relay becomes On during TON time. Then, relay becomes Off.



While the device is energized, If START input is active, first TON and then TOFF times are passed periodically. As soon as START becomes passive, timer stops and initial

conditions are returned.

If START input is active, relay becomes On during TON time. Then, relay becomes Off.

While the device is energized,

Powe

Start


Reset

Relay

While the device is energized,

While the device is energized.


a time delay (TON).



If START input is active, relay becomes Off and On periodically during TOFF and TON times respectively. At the end of each TON time START input is checked. If it START is passive, timer stops and initial conditions are returned. Otherwise, periodic operation continues.

While the device is energized, If START is active, relay is energized after delay time (TOFF).

# **TERMINAL CONNECTIONS**




#### **Terminal description**

- 2 : Solid state out (Max 30V 100mA, open collector NPN)
- 3 : Reset input (Max 30V) 4 : Start input (Max 30V) 5 : Gate input(Max 30V)
- 6 : GND
- 7 : +12V 30mA auxiliary supply output for sensors 8,9 : SUPPLY input 10,11,12 : Relay contacts (Max 2A 250V AC)


# **TYPICAL SENSOR CONNECTIONS**

## Typical connections for PNP sensor type



NOTE: FOR PNP SENSOR TYPE ACTIVE LEVEL IS AUXILIARY POWER SUPPLY VOLTAGE.

## Typical connections for NPN sensor type



NOTE: FOR NPN SENSOR TYPE ACTIVE LEVEL IS GROUND (GND).